

Certificato di Costanza della Prestazione 0987-CPR-197

In ottemperanza al Regolamento UE 305/2011 e in relazione alle leggi, regolamenti e procedimenti amministrativa degli Stati Membri concernenti i prodotti da costruzione, si stabilisce che:

il prodotto da costruzione denominato:

PANNELLO TRUCIOLARE GREZZO "FIRPAN"

Descrizione del prodotto:

Tipologia:	Pannello grezzo in particelle di legno (pannello truciolare) spessore da 10 a 38 mm
Impiego:	Pannello in particelle di legno legate con resina (pannello truciolare)
Posa in opera:	Utilizzo interno come componente non strutturale in ambiente secco Parete/soffitto non in aderenza - Pavimento appoggiato a supporto incombustibile

Prodotto da:

FRATI LUIGI S.p.A.

Via XX Settembre, 58 - 46030 POMPONESCO (MN) - (Italy)

nello stabilimento di

Sito Produttivo Pantec - Via Brasilia, 31, 32 - 46034 BORGIO VIRGILIO (MN) - (Italy)

è sottoposto dal produttore al controllo di produzione aziendale (FPC) secondo Sistema 1 e alle prove iniziali di tipo (ITT) da Organismo Notificato per Certificazione Ispezione e Prova ai sensi Regolamento UE 305/2011. L'organismo di certificazione (LAPI S.p.A. - Laboratorio Prevenzione Incendi N° 0987) ha effettuato le prove sperimentali richieste su campioni prelevati nello stabilimento secondo un piano di prove prestabilito per verificare le caratteristiche intrinseche del prodotto; ha effettuato la verifica iniziale presso lo stabilimento e il controllo di produzione aziendale ed eseguirà la sorveglianza continua per la verifica ed approvazione del controllo di produzione aziendale

Questo certificato attesta che tutti i procedimenti relativi al Sistema 1 ed i requisiti riportati nell'allegato ZA dello standard

EN 13986:2004+A1:2015

(limitatamente ai pannelli per utilizzo non strutturale)

"Pannelli a base di legno per l'utilizzo nelle costruzioni - Caratteristiche, valutazione di conformità e marcatura"

sono applicati e che il prodotto soddisfa i requisiti richiesti per quanto riguarda:

Resistenza a flessione EN 310
Resistenza a trazione EN 319
Rilascio di formaldeide: classe E1

Inoltre il prodotto presenta Euroclasse di reazione al fuoco secondo la norma EN 13501-1:2018

B - s2, d0 (Per applicazione a parete o soffitto)

B_{fl} - s1 (Per applicazione a pavimento)



Questo rinnovo del certificato, emesso per la prima volta in data 16/12/2013, è stato rilasciato in data 16/12/2023 e rimane valido al permanere delle condizioni richiamate nelle specifiche tecniche armonizzate o fino a che non vengano introdotte variazioni a livello sia del prodotto che del controllo di produzione fino al 15/12/2028.

Prato, 16/12/2023

Il Direttore Tecnico
Dr. Luca Ermini

Certificate of Constancy of Performance 0987-CPR-197

In compliance with the Regulation UE 305/2011 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products, it has been stated that the construction product:

the building product denominated:
PANNELLO TRUCIOLARE GREZZO "FIRPAN"

Description of the product:

Raw particle-board panel - thickness from 10 mm to 38 mm

Type: Resin – bound particle-board panel
Use: Internal use as non-structural component in dry conditions
End use: Wall / ceiling, not laid on any support - Floor covering in contact on non-combustible substrate

Produced by:

FRATI LUIGI S.p.A.

Via XX Settembre, 58 - 46030 POMPONESCO (MN) - (Italy)

in the factory of:

Sito Produttivo Pantec - Via Brasilia, 31, 32 - 46034 BORGIO VIRGILIO (MN) - (Italy)

is submitted by the manufacturer to the factory production control (FPC) under system 1 and to the testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Regulation UE 305/2011.

The Notified Body (LAPI SpA - Laboratorio Prevenzione Incendi N° 0987) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control

This certificate attests that all provisions concerning to the System 1 and the performances described in Annex ZA of the standard

EN 13986:2004+A1:2015

(for non-structural use only)

"Wood-based panels for use in construction – Characteristics, evaluation of conformity and marking"

are performed and the product complies with characteristics required as for:

Bending strength EN 310
Tensile strength EN 319
Release of formaldehyde : Class E1

Moreover Euroclass for reaction to fire according to EN 13501-1:2018 is

B - s2, d0 (For application to wall or ceiling)

B_{fl} - s1 (For application to floor)



This renew of certificate, first issued on 16/12/2013, has been released on 16/12/2023 and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest on 15/12/2028.

Prato, 16/12/2023

Il Direttore Tecnico

Dr. Luca Ermini